



Addendum
No. THREE Date: 08.27.2020

Project:

**KEY SPRINGS RENOVATIONS 2020
FOR THE
HAMILTON HOUSING COMMUNITY
HAMILTON, ALABAMA
(MCKEE PROJECT NO. 2020-154)**

The following modifications/ changes and/or substitutions to the plans and specifications are hereby made a part of same and are incorporated in full force as part of the contract documents.

Bidders shall acknowledge receipt of this Addendum in writing on their Proposal Form.

A1.1 GENERAL MODIFICATIONS or CLARIFICATIONS:

- A. Refer to Electrical Specification Section 2.21, which states: Romex wiring will be allowed for branch circuitry if approved for use by the local authority having jurisdiction.
1. Note that the owner prefers to use Romex at interior conduit locations as allowed by code officials, but Romex shall not be allowed at Exterior conduit locations.
 2. General Contractor shall verify with local code official if there are any restrictions on the use of Romex for this project.
 3. Refer to Electrical Specification Section 2.02 & 3.13, which states the requirements for exterior use of rigid conduit.

A1.2 SPECIFICATION MODIFICATIONS:

- A. Refer to Specification Section 08520: page 4 "GLASS & GLAZING": Windows are NOT required to be TEMPERED GLASS, except where required by code. Window manufacturer shall verify all code required locations and provide tempered glass accordingly.
- B. Refer also to window elevations, details and notes on drawings.

A1.3 DRAWING MODIFICATIONS:

- A. NONE

A1.4 ATTACHMENTS:

- B. NONE

END OF ADDENDUM